

**CERTIFICATE OF STRUCTURAL SOUNDNESS**  
**ANNEXURE TO STATEMENT ACCOMPANYING FORM "A"**


This is to certify that we have inspected the **School Building** of **S.B.O.A. Global School** located at **T. S. No. 65, S. Nos. 127 Part, 128 Part, 141 Part & 142 Part, Plot No. R15/1, W- Block, C - Sector, 6th Street, "Anna Nagar West Extension", Padi Village, Chennai - 600 101, Ambattur Taluk, Tiruvallur District.** This **School Premise** consists of **R.C.C. Roof Building** constructed in the year **2017**.

This certificate covers the above mentioned buildings only and does not cover any other buildings or structures such as thatched sheds, semi / non permanent structures, compound wall, etc. This certificate does cover any building partly completed / building under construction. I hereby advise that the periodical repairs & renovations shall be carried out to the entire buildings regularly.

e found that there were no visible defects noticed in the building and it is **Structurally Sound** to run the **School**. This certificate does not include any eventualities caused by all natural calamities. If any fire accident / or any other mishap occurs I am not held responsible. Access to open terrace is to be kept lock & key positon. All electrical panel boards / main switches / cables / generator / electical maintenance room has to be kep in safety with lock & key positon. The U.G. Sump, manholes, OHT inspection chamber, septic tank openings has to be sealed with cover slab. Structural alterations / deviations should not be carried out to any of the buildings without prior permission from the competent authority. If any above mentioned aspects would be found violated at a later date after issue of this certificate / license, I am not held responsible for any eventualities caused and this certificate gets invalid.

Date : 20-05-2020



  
Signature of the Panel Engineer <sup>20/05/2020</sup>  
Registration No. 30251/05/D1, Class - 1A

**Er. B.S. VIJAYAKUMAR,**  
M.E. (Struct), FIV, MIE, C.Eng.,  
Structural Engineer, Chartered Engineer,  
Panel Engineer to issue Stability Certificate,  
Licensed Surveyor, Approved Valuer for Banks,  
Registered Valuer of Income Tax Dept.,  
No. 14, E.M.K. Street,  
Palavanthangal, Chennai-600 114

**FORM - B**

**STATEMENT TO ACCOMPANY THE CERTIFICATE OF  
STRUCTURAL SOUNDNESS**

Location of the building, Door No., Street Name & Name of the Place.	Age of the building	Value of the Building Rs.	No. of Storeys & Area	Short Description of structure, Steel, RCC framed or load bearing masonry.
S.B.O.A. Global School, T. S. No. 65, S. Nos. 127 Part, 128 Part, 141 Part & 142 Part, Plot No. R15/1, W- Block, C - Sector, 6th Street, "Anna Nagar West Extension", Padi Village, Chennai - 600 101, Ambattur Taluk, Tiruvallur District.	2017 - 3 years	Rs.5.50 Crore	G+2 Floor only  G.F. = 11,733 sq.ft F.F. = 11,733 sq.ft S.F. = 11,733 sq.ft  Total = 35,199 sq.ft	R.C.C. Roof Framed Structure

Purpose for which the building is certified	The period for which the building will be structurally sound	No. of Persons accommodated	Remarks
Educational purpose - S.B.O.A. Global School	01-06-2020 To 31-05-2023 (For 3 years only)	About 800 students	This certificate does not cover any thatched shed and other non permanent structure. This certificate does not cover any casualties caused due to natural calamities.

Date : 20-05-2020



*B.S. Vijayakumar*  
Signature of the Panel Engineer 20/05/2020  
Registration No. 30251/05/D1, Class - 1A

**Er. B.S. VIJAYAKUMAR,**  
M.E. (Struct), FIV, MIE, C.Eng.,  
Structural Engineer, Chartered Engineer,  
Panel Engineer to issue Stability Certificate  
Licensed Surveyor, Approved Valuer for Banks  
Registered Valuer of Income Tax Dept.,  
No. 14, E.M.K. Street,  
Palavanthangal, Chennai-600 114

FORM - C

Form of certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act 1965 (Tamil Nadu Act 1 of 1965) referred to in rule 4 of the Tamil Nadu Public (Licensing) Rules, 1966.

**1. Foundation :**

- a. Depth below ground level : 2.44 m from G.L
- b. Nature of soil met with at foundation level. : Clayey, Sandy & Silty soil
- c. Pressure at foundation : 160 KN/sq.m
- d. Probable safe bearing capacity of the soil strata met with at foundation : 180 KN/sq.m

**2. Superstructure :**

- a. Maximum stress in the most critical section of masonry and concrete : Brick masonry = 4.00 N/mm<sup>2</sup>  
M20 Grade Concrete = 5.00 N/mm<sup>2</sup>
- b. Nature of masonry and concrete and its safe permissible stress : Brick masonry = 4.50 N/mm<sup>2</sup>  
M20 Grade Concrete,  $\sigma_{cbc}$  = 7.00 N/mm<sup>2</sup>

The structural soundness of the building has been verified by me with reference to ISI loading standards, IS : 875 (Latest version) and other relevant Indian Standard Code of practices. I declare that the building is **Structurally Sound** to be used as a **Public building** for the purpose as noted in the statement.

A licence may be granted for the period from 01-06-2020 To 31-05-2023 (For 3 years only)

Date : 20-05-2020



*B.S. Vijayakumar* 20/05/2020  
Signature of the Panel Engineer  
Registration No. 30251/05/D1, Class - 1A

Er. B.S. VIJAYAKUMAR,  
M.E. (Struct), FIV, MIE, C.Eng.,  
Structural Engineer, Chartered Engineer,  
Panel Engineer to issue Stability Certificate.  
Licensed Surveyor, Approved Valuer for B&S  
Registered Valuer of Income Tax Dept.,  
No. 14, E.M.K. Street,  
Palavanthangal, Chennai-600 114

**Er. B.S. VIJAYAKUMAR,**  
B.E.(Civil), M.E.(Struct), M.Sc.(REV), FIV, MIE, C.Eng (I),  
Civil Engineer, Structural Engineer,  
Chartered Engineer, Govt. Approved Valuer,  
Registered Valuer of Income Tax Dept. & IBBI,  
Panel Engineer to issue Stability Certificate-Class 1A

**OFF :**  
No. 14, E. M. K. Street,  
Palavanthangal,  
(Near Palavanthangal Subway),  
Chennai - 600 114.  
Mobile : 94434 17931, 86107 00968  
E-mail : vijayassociates64@gmail.com

**Registered Valuer of IBBI : Regd. No. IBBI / RV / 02 / 2018 / 10244**  
**Registered Valuer of Wealth Tax Act. - 1957 - 34AB : Regd. No. Category - I / 643 of 2005-06**

**STRUCTURAL SOUNDNESS CERTIFICATE**

**STATEMENT ACCOMPANYING FORM - A**

1. Name of the Building : **S.B.O.A. Global School**
2. Location (Street No. ward No. Name of place, ie Corporation Municipality/Town Panchayat) : **T. S. No. 65, S. Nos. 127 Part, 128 Part, 141 Part & 142 Part, Plot No. R15/1, W- Block, C - Sector, 6th Street, "Anna Nagar West Extension", Padi Village, Chennai - 600 101, Ambattur Taluk, Tiruvallur District. Mrs. Renuka Samson, Head Mistress, Mobile : 98844 06944**
3. Year of construction : **2017, R.C.C. Roof, G+2 Floors**
4. Approximate cost of construction as per current rate : **Rs.5.50 Crore**
5. Purpose for which the building is being used or proposed to be used : **Educational purpose - S.B.O.A. Global School**
6. Purpose for which the building has hitherto been used : **Educational purpose - S.B.O.A. Global School**
7. Details of construction of the building (particulars) of the foundation, soil specification of various parts as under
  - a. Foundation : **R.C.C. Column footing foundation**
  - b. Basement : **Plinth Beam & Brick work in C.M 1:5**
  - c. Superstructure : **R.C.C. Columns, Beams & Infilled brick masonry walls**
  - d. Roof : **R.C.C. Roof**
  - e. Flooring : **Vitrified Ceramic tiles flooring**
8. Period for which licence is required : **01-06-2020 To 31-05-2023 (For 3 years only)**
9. No. of persons to be accommodated : **About 800 students**

Date : 20-05-2020



*Bhannu 20/05/2020*  
Signature of the Panel Engineer  
Registration No. 30251/05/D1, Class - 1A  
**Er. B.S. VIJAYAKUMAR,**  
M.E. (Struct), FIV, MIE, C.Eng.,  
Structural Engineer, Chartered Engineer,  
Panel Engineer to issue Stability Certificate,  
Licensed Surveyor, Approved Valuer for Banks,  
Registered Valuer of Income Tax Dept.,

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

Date : 20-05-2020

Signature of the Owner of the Building